

CITY OF DAPHNE
BUREAU OF FIRE PREVENTION
FOOD TRUCK/CONCESSION TRAILERS INSPECTION CHECKLIST



**DAPHNE FIRE
DEPARTMENT**

VENDOR NAME: _____ **DATE:** _____

CONTACT NAME: _____ **PHONE:** _____

ITEM	SAT	UNSAT	N/A	ITEM	SAT	UNSAT	N/A
GENERAL SAFETY				FIRE SUPPRESSION SYSTEM			
1) Current City Business License				1) Portable ABC Fire Extinguisher			
2) Current Health Department Permit				A. Minimum 2A:10BC			
3) Minimum 10 ft. clearance around unit				B. Current certification tag			
4) Adequate fire department access				C. Visible and accessible			
POWER SOURCE (GENERATORS) & FUEL SUPPLY				2) Portable Class K Fire Extinguisher			
1) All electrical complies with NFPA 70				A. Minimum 2.5 gallon Class K			
2) Protective barrier around generator				B. Current certification tag			
LP-GAS SYSTEM				C. Visible and accessible			
1) Current inspection on LP gas system				3) Hood System / Fire Extinguishing System			
2) Leak test completed & documented				TYPE 1 HOOD SYSTEM REQUIRED FOR FRYING OR GRILLING OPERATIONS			
3) Hose assembly marked for LPG use				A. Current certification tag (6 Months)			
4) Hose equipped with factory fittings				B. Manual pull station			
5) No CSST Piping installed in trailer/truck				C. Filters clean / in place			
6) Gas connections/ T's located beneath unit				D. UL-300 compliant			
7) Grommets around all pipe penetrations				E. Proper head placement with appliances			
8) Main shut off valve accessible				F. Utility controls / Auto shutoffs installed			
LP-GAS CONTAINERS							
1) Portable containers upright & secure							
2) Container within 10 yr. manufacturer date							
3) Installed outside vehicle or in cabinet							

This APPROVED inspection form serves as your permit for the City of Daphne, Alabama for one (1) year from the date below. Any modifications or alterations of appliances, operating procedures or safety equipment may void this permit, and the Fire Marshal's office shall be notified to schedule a reinspection.

CORRECTIVE ACTION SHALL BE CARRIED OUT IMMEDIATELY TO CORRECT ALL VIOLATIONS NOTED.

THE FIRE MARSHAL'S OFFICE DOES NOT GRANT PERMISSION OR APPROVAL OF A BUSINESS/OPERATION WHERE VIOLATIONS EXIST. NOTIFY THIS OFFICE AS CORRECTIVE ACTIONS ARE COMPLETED AT 251-620-0781.

FIRE OFFICIAL: _____ **DATE:** _____

OCCUPANT: _____ **DATE:** _____